



Ref. Certif. No.

**SE-113587**

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

### CB TEST CERTIFICATE

Product	Smart String-level Disconnect (SSLD)
Name and address of the applicant	Shenzhen SOFARSOLAR Co., Ltd. 11/F., Gaoxingqi Technology Building, No.67 Area, Xingdong Community, Xin'an Sub-district, Bao'an District, Shenzhen City, China
Name and address of the manufacturer	Same as applicant
Name and address of the factory <i>Note: When more than one factory, please report on page 2</i>	Guangdong Sofar Smart Solar Technology Co., Ltd. No.1, Dongsheng North Road, Chenjiang Street, Zhongkai High-tech Zone, Huizhou City (One license multiple addresses), China <input type="checkbox"/> Additional Information on page 2
Ratings and principal characteristics	Ue= 1500Vdc, 8 poles, IP66 (normal installation) In= 20A, Icu=Ics=24A Ui = 1500Vdc, Uimp = 8kV Utilization category: A Reference temperature: +40°C
Trademark / Brand (if any)	
Customer's Testing Facility (CTF) Stage used	-
Model / Type Ref.	SOFAR 320KTLX0, SOFAR 250KTLX0, SOFAR 330KTLX0, SOFAR 333KTLX0, SOFAR 350KTLX0, SOFAR 333KTLX1, SOFAR 330KTLX1. SOFAR 350KTLX1
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional Information on page 2
A sample of the product was tested and found to be in conformity with	IEC 60947-1:2007+A1+A2 IEC 60947-2:2016+A1
As shown in the Test Report Ref. No. which forms part of this Certificate	2311A1381SHA-001

This CB Test Certificate is issued by the National Certification Body

**Intertek Semko AB**  
Torshamnsgatan 43  
Box 1103  
SE-164 22 Kista, Sweden  
Date: 18 March, 2024

**intertek**

Signature:

Anneli Averland Johansson